



CENTRO DI RICERCA E
SPERIMENTAZIONE PER L'INDUSTRIA
CERAMICA

SEDE

Via Martelli, 26 - 40138 Bologna
Tel. (051) 534015 - Fax. (051) 530085

CERTI.CER.

LABORATORIO DI ZONA
Via Valle d'Aosta, 1 - 41049 Sassuolo
Tel. e Fax. (0536) 802154

Part. IVA 0094778-0375

Bologna, 19/02/14

Spett. le
BASALTINA S.r.l.
Stabilimento Loc. Ponzano
01022 BAGNOREGIO (VT)

TEST LABORATORY

TEST REPORT No. 2413/14

(traslation of test report No. 2411/14 of 19/02/14)

Requested by:	BASALTINA S.r.l. Stabilimento Loc. Ponzano 01022 BAGNOREGIO (VT)
On (date):	13/02/14
For the sample marked:	"PIETRA BASALTINA - Tipo CONTROFALDA - Finitura Stuccata a cemento e levigata - Cava provenienza materiale: c/o BASALTINA S.r.l. - Località Ponzano snc - 01022 Bagnoregio (VITERBO)".

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our supervision.

The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 3 pages this cover included.



Consorzio universitario per la gestione del
«Centro di ricerca e sperimentazione per
l'industria ceramica».
D.P.R. 10-4-1978 n. 806
(G.U. 20-12-1978 n. 353)

Laboratorio autorizzato ad effettuare il
servizio di rilevamento dell'inquinamento
atmosferico.
Decreto MINISTERO SANITÀ 10-8-1974
(G.U. 14-9-1974 n. 240)

Laboratorio iscritto nell'albo dei «Laboratori Esterni
Pubblici e Privati Altamente Qualificati».
Decreto MINISTERO RICERCA SCIENTIFICA 6-6-1983
(G.U. 6-7-1983 n. 183)

Membro ASTM
American Society for
Testing and Materials.

CERLABS EUROPEAN NETWORK OF NATIONAL CERAMIC LABORATORIES - ITALIAN MEMBER

CENTRO CERAMICO - BOLOGNA

Test report No. 2413/14 Date 19/02/14

Page 2 of 3

Description of the sample:

Stone slab 50 x 120 x 2.0 cm marked "PIETRA
BASALTINA - Tipo CONTROFALDA - Finitura Stuccata a
cemento e levigata - Cava provenienza materiale: c/o
BASALTINA S.r.l. - Località Ponzano snc - 01022
Bagnoregio (VITERBO)".

Manufacturer: -----

Sampling details:

- Where: -----
- Date: -----
- By whom: CUSTOMER
- How (methods): -----

DATE OF RECEIVAL IN LABORATORY: 13/02/14

TESTS PERFORMED:


		Date of starting	Date of ending
<input checked="" type="checkbox"/>	DIN 51130 Determination of the anti - slip properties - (06/2004) Workrooms and fields of activities with raised slip danger, walking method - ramp test	17/02/14	17/02/14

**DIN 51130 (06/2004)- Determination of the anti - slip properties –
Workrooms and fields of activities with raised slip danger, walking
method – ramp test**

Surface characteristics

- Smooth
- Profiled
- Structured
- Rough

OPERATIVE CONDITIONS



RESULTS


Average total acceptance angle:
Movement area (cm³/dm²):

8.8°

CLASSIFICATION (BGR 181- 10/2003)

Group of anti - slip properties:
Movement area evaluation group:

R9



Prof. Eng. Giorgio Timellini
Director